தமிழ்நாடு தீயணைப்பு மற்றும் மீட்புப் பணிகள் துறை தீயணைப்பு மீட்பு பணி நிலையம், பொன்னேரி

தடையின்மை சான்று

வ.எண்: 07/2022

ந.க.எண்: 81/V/பொன்/2022

நாள்: 25.02.2022

பொருள்:

தீயணைப்பு - மீட்புப்பணிகள் நிலையம் பொன்னேரி - பள்ளிக்கூடம் நிறுவிட / பள்ளிக்கூடத்திற்கு அங்கீகாரம் வழங்கிட தடையின்மை சான்று வழங்குதல் - குறித்து.

பார்வை:

1. அரசு ஆணை எண்.122, பள்ளிக் கல்வி (2) துறை நாள் : 14.09.2004 2. அரசு ஆணை எண்.123, பள்ளிக் கல்வி (2) துறை நாள்: 14.09.2004 3. The Principal Velammal International School என்பவரிடம்

பெறப்பட்ட விண்ணப்பம். நாள்: 23.02.2022

பார்வையில் காணும் அரசு ஆணைகள் மற்றும் விண்ணப்பத்தின் படி திருவள்ளூர் மாவட்டம், பொன்னேரி வட்டம், பஞ்செட்டி, பொன்னேரி ரோடு, கொல்கத்தா சாலை, என்ற முகவரியில் நிறுவ/நிறுவப்பட்டுள்ள THE VELAMMAL INTERNATIONAL SCHOOL (VELAMMAL KNOWLEDGE PARK) என்ற பள்ளியினை 25.02.2022 அன்று நிலைய அலுவலர், திரு.த.சம்பத் என்பவரால் ஆய்வு செய்யப்பட்டது. இவ்விடத்தில் பள்ளிக்கூடம் நிறுவிட/ பள்ளிக்கூடத்திற்கு அங்கீகாரம் வழங்கிட தீயணைப்பு மற்றும் மீட்புப் பணி பணி நோக்கிலிருந்து யாதொரு தடையும் இல்லை எனச் சான்றிடலாகிறது.

குறிப்பு:

இச்சுகூறு நடிழ்த்தபட்ட நாளிலிருந்து ஒரு வருடத்திற்கு மட்டும் செல்லத்தக்கது

தேதியுடன் தூடி அலுவல்க் முத்த

The Principal,

THE VELAMMAL INTERNATIONAL SCHOOL, VELAMMAL KNOWLEDGE PARK

KOLKATTA HIGH ROAD, PANJETTI, PONNERI TALUK, THIRUVALLUR DISTRICT.

560.

1. மாவட்ட அலுவலர் திருவள்ளூர் மாவட்டம், திருவள்ளூர்.

2. நிலைய அலுவலர் பொன்னேரி.

ந்லையு அனிவனர் தீயணைப்பு (ம) மீழுப் பணிகள் நிலையுக் பொன்னேரி – 601 204

FIRE AND RESCUE STATION

PONNERI, THIRUVALLUR -601204

R.C No: ... 81./ V/DAm) 1000.

NO OBJECTION CERTIFICATE

SUB: issuing of No objection certificate for school recognition, in the jurisdiction of ponneri- Fire & rescue station .

Ref:

- 1. GO/MS 122 Dt: 14:09.3014/Dept. Of school Education, Tamilnadu.
- 2. GO/MS 123 Dt: 14. 99. 2014./Dept. Of school Education, Tamilnadu.
- 3. Application from correspondent / principal / head master of THE VELAMMAL INTERNATIONAL SCHOOL.

CONDITION

- 1. Inspection will be done whether the installed fire safety systems are maintained well and Renewal of this NOC is Mandatory EVERY YEAR starting with the expiry of one year of obtaining Occupancy NOC.
- 2. If here is any deviation from the Govt. Rule and Act, the NOC issued will stand canceled.

3. Fire fighting trained employee must be available in the premises to operate the equipment.

To 25.37 25.27

நகைய இரும்பும் பண்கள் நிலையம் பொன்னேரி – 601 204

1. The District officer (Thiruvallur-sub-urban), Tamilnadu fire & Rescue services, Thiruvallur.

2.office copy

FIRE AND RESCUE DEPARTMENT

FORM/41

(ACT 250/(3))

Form No: Date:

NO OBJECTION CERTIFICATE

Sub: please subject to fire / No objection certificate / Reg;

Ref: Your application

THE VELAMMAL INTERNATIONAL SCHOOL Kolkata high road panchetti, ponneri 601 204 was inspected on lay district officers.

/TRANSLATED TAMIL TO ENGLISH VERSION/
TAMILNADU FIRE AND RESCUE SERVICES

Second floor –
Third floor -
Has (G+1) and named "the Velammal international school" the constracted buildings has been declared hat the mentioned institution Has been built according to the norms and rules of fire and rescue department.

This is to certify that there is no objection to run the institution in the above mentioned place this certificate is valid for one year from the date of issue .

To

The correspondent

Ground floor -

First floor

Velammal international school

As per inspected, the place measure

Kolkata high road panchetti

Ponneri 601204

/TRANSLATED TAMIL TO ENGLISH VERSION/

TAMILNADU FIRE AND RESCUE SERVICES DEPARTMENT REQUIREMENTS OF FIRE SAFTY INATALLATIONS AND LIFE SAFTY MEASURES FOR VARIOUS CATEGORIES

Group B: Educational Buildings (Less Than 15 Mts in Height, Ground + One Storey)

SL.No	Types of fire protection (required (active measures)	Requirements
1	Fire Extinguishers	Minimum 2 No's per floor
2	Automatic sprinkler system	Only for basement area if the area is more than 200 Sq.m
3	Terrace Level over head tank	5000 Liters capacity.
4	Fire pump at Terrace Level	Only for basement area, pump of capacity 450LPM.
	Life safety (Passive Measure)	
5	Staircase (1.5 mts width)	2 Nos should not be adjacent and Away from each other.
6	Side net back area	As per DCR in CMDA Area

நலைய் அயுவ**லர்** தீயணைப்பு (ம்) மீட்டிப் பணிகள் நிலையக் பொன்னேரி – 601 204